

**CITY OF PALO ALTO
BUILDING INSPECTION DIVISION
CORRECTION LIST**

Date: June 24, 1999
Subject: Residential two story addition
Address: 2330 Bryant Street
Plan Check # 99-1283
Reviewed by: Carroll Woods

IMPORTANT NOTICE: Please return this correction list along with two sets of revised drawings and calculations when resubmitting. Please reference on the correction list where on the plans the corrections have been made to assist in providing a more timely review.

Comments:

1. All sheets of plans shall be revised to correct the title block to show the scope of work is an addition and remodel to an existing house.
2. Plans shall be revised as follows:
 - a. Provide fireplace data on the plans. Show glass doors, combustion air, hearth materials and dimensions, etc. Provide brand name, and ICBO approval number.
 - b. Provide construction details at level landings at all exterior doors. Maximum drop from interior floor level to slab at landing is 8 inches. Provide details for landing slab against wood floor framing. See new porch slab at front door, laundry door, living room door, etc.
 - c. Revise the floor plan to show the framing supporting the second floor over the garage is protected with 5/8" type X gyp. board. See ceiling, and northwest side wall in garage.
 - d. Clarify plans to show stucco construction section showing plywood sheathing, two layers of grade D paper, 7/8" thick stucco (3 coats), and weep screed at sill line.
 - e. Clarify roofing section on detail 14/A-2 to show required underlayment is 15# roofing felt. Minimum Class C roofing materials are required.

